

6-2009

Development of a Wireless Sensor Network to Quantify Hydrogen Sulfide Concentrations in Swine Housing

Randy John Swestka
Iowa State University

Robert T. Burns
Iowa State University

Lun Tong
Iowa State University

Steven J. Hoff
Iowa State University, hoffer@iastate.edu

Hong Li
Iowa State University

Follow this and additional works at: http://lib.dr.iastate.edu/abe_eng_conf

 *next page for additional authors*
Part of the [Bioresource and Agricultural Engineering Commons](#)

The complete bibliographic information for this item can be found at http://lib.dr.iastate.edu/abe_eng_conf/154. For information on how to cite this item, please visit <http://lib.dr.iastate.edu/howtocite.html>.

Development of a Wireless Sensor Network to Quantify Hydrogen Sulfide Concentrations in Swine Housing

Abstract

Previous research by our team to develop a wireless hydrogen sulfide (H₂S) detection system for use in swine housing indicate a multi-point detection system is needed to characterize in-house H₂S concentrations both spatially and temporally during slurry agitation. Pulsed fluorescence H₂S analyzers, while highly accurate at H₂S concentrations less than 20 ppm, require asynchronous sampling to accommodate multiple measurement points with a single analyzer. Additionally, pulsed fluorescence H₂S analyzers are not designed to measure the high H₂S concentrations associated with burst releases during deep-pit swine manure agitation. The dynamic nature of the environment necessitates simultaneous sampling of multiple points with a sensor that can respond to very high (100 – 500 ppm) H₂S concentrations. This can be accomplished through the use of electrochemical sensors that have demonstrated the ability to perform similarly to pulsed fluorescence at high concentrations. The objective of this project was to develop a wireless H₂S sensor network that can be used to characterize the spatial distribution of H₂S that workers and swine in pork production facilities are exposed to in different facility types during different operating conditions. The wireless H₂S sensor network developed in this project was designed to meet the following operational criteria: a) less than 5% sensor drift per 1000 ppm-hours, b) up to 50 m range, c) data collection interval less than 90 seconds, and e) H₂S detection range of 0-500 ppm.

Keywords

Wireless sensor network, WSN, hydrogen sulfide, spatial and temporal H₂S distribution, swine manure agitation, mesh network, Zigbee

Disciplines

Bioresource and Agricultural Engineering

Comments

This is an ASABE Meeting Presentation, Paper No. [096640](#).

Authors

Randy John Swestka, Robert T. Burns, Lun Tong, Steven J. Hoff, Hong Li, Nir Keren, Hongwei Xin, Robert Spajic, and Ross V. Muhlbauer



2950 Niles Road, St. Joseph, MI 49085-9659, USA
269.429.0300 fax 269.429.3852 hq@asabe.org www.asabe.org

An ASABE Meeting Presentation

Paper Number: 096640

Development of a Wireless Sensor Network to Quantify Hydrogen Sulfide Concentrations in Swine Housing

Randy Swestka

Agricultural and Biosystems Engineering, Iowa State University, 3155 NSRIC Ames, IA 50011, rjswestk@iastate.edu

Robert Burns, Ph. D., Professor

Agricultural and Biosystems Engineering, Iowa State University, 3224 NSRIC, Ames, IA, 50011, rburns@iastate.edu

Lun Tong, Ph. D., Adjunct Assistant Professor

Agricultural and Biosystems Engineering, Iowa State University, 200C Davidson Hall, Ames, IA, 50011, luntong@iastate.edu

Steve Hoff, Ph. D., Professor

Agricultural and Biosystems Engineering, Iowa State University, 212 Davidson Hall, Ames, IA, 50011, hoffer@iastate.edu

Hong Li, Ph. D., Assistant Scientist

Agricultural and Biosystems Engineering, Iowa State University, 1242A NSRIC, Ames, IA, 50011, lwblue@iastate.edu

Nir Keren, Ph. D., Assistant Professor

Agricultural and Biosystems Engineering, Iowa State University, 102 Industrial Education Building 2, Ames, IA, 50011, nir@iastate.edu

Hongwei Xin, Ph. D., Professor

Agricultural and Biosystems Engineering, Iowa State University, 3204 NSRIC, Ames, IA, 50011, hxin@iastate.edu

Robert Spajic

Agricultural Faculty Osijek, University of J.J. Strossmayer Osijek, Trg Sv. Trojstva 3, Osijek, 3100, Croatia, rspajic@iastate.edu

Ross Muhlbauer, Research Associate

Agricultural and Biosystems Engineering, Iowa State University, 3252 NSRIC, Ames, IA, 50011, rmuhlbar@iastate.edu

**Written for presentation at the
2009 ASABE Annual International Meeting
Sponsored by ASABE
Grand Sierra Resort and Casino**

The authors are solely responsible for the content of this technical presentation. The technical presentation does not necessarily reflect the official position of the American Society of Agricultural and Biological Engineers (ASABE), and its printing and distribution does not constitute an endorsement of views which may be expressed. Technical presentations are not subject to the formal peer review process by ASABE editorial committees; therefore, they are not to be presented as refereed publications. Citation of this work should state that it is from an ASABE meeting paper. EXAMPLE: Author's Last Name, Initials. 2009. Title of Presentation. ASABE Paper No. 09----. St. Joseph, Mich.: ASABE. For information about securing permission to reprint or reproduce a technical presentation, please contact ASABE at rutter@asabe.org or 269-429-0300 (2950 Niles Road, St. Joseph, MI 49085-9659 USA).

Reno, Nevada
June 21 – June 24, 2009

Abstract. *Previous research by our team to develop a wireless hydrogen sulfide (H₂S) detection system for use in swine housing indicate a multi-point detection system is needed to characterize in-house H₂S concentrations both spatially and temporally during slurry agitation. Pulsed fluorescence H₂S analyzers, while highly accurate at H₂S concentrations less than 20 ppm, require asynchronous sampling to accommodate multiple measurement points with a single analyzer. Additionally, pulsed fluorescence H₂S analyzers are not designed to measure the high H₂S concentrations associated with burst releases during deep-pit swine manure agitation. The dynamic nature of the environment necessitates simultaneous sampling of multiple points with a sensor that can respond to very high (100 – 500 ppm) H₂S concentrations. This can be accomplished through the use of electrochemical sensors that have demonstrated the ability to perform similarly to pulsed fluorescence at high concentrations. The objective of this project was to develop a wireless H₂S sensor network that can be used to characterize the spatial distribution of H₂S that workers and swine in pork production facilities are exposed to in different facility types during different operating conditions. The wireless H₂S sensor network developed in this project was designed to meet the following operational criteria: a) less than 5% sensor drift per 1000 ppm-hours, b) up to 50 m range, c) data collection interval less than 90 seconds, and e) H₂S detection range of 0-500 ppm.*

The developed wireless H₂S sensor network will be utilized in deep pit swine facilities during normal operating conditions, as well as during pit agitation and removal events to monitor H₂S concentration and spatial distribution.

Keywords. Wireless sensor network, WSN, hydrogen sulfide, spatial and temporal H₂S distribution, swine manure agitation, mesh network, Zigbee

Introduction

Hazardous high concentration hydrogen sulfide (H_2S) burst releases can occur during swine manure slurry agitation. Manure slurry is commonly land applied as a fertilizer for crop production. Slurry agitation is needed to suspend the settled solids for removal from storage and land application to crop production fields. One swine confinement design is a deep-pit building with the animal occupied zone (AOZ) separated from the manure slurry storage area by a slotted floor.

Humans frequent the AOZ as caretakers of the swine. During slurry agitation dangerous conditions can exist in the AOZ caused by H_2S gas escaping the manure slurry storage area through the slotted floor into the animal area. While it is never recommended a human enter a swine house during slurry agitation, entries still occur.

Repeated exposure to H_2S can cause respiratory problems and other illnesses in humans; exposure to high H_2S concentrations possible during slurry agitation and removal events can lead to death (Donham 1990; Donham and Gustafson 2004). Hydrogen sulfide poisoning also occurs in swine. Swine losses to H_2S poisoning can still occur when precautions are taken to avoid swine loss (Puck, 2008). Custom manure applicators report that when loss is randomly scattered throughout the building the swine succumb to H_2S poisoning were most likely lying on the slotted floor nearest the pit headspace. Other times when swine loss is localized to an area, insufficient ventilation (natural or mechanical) or unfavorable airflow patterns to prevent accumulation of H_2S is suspected to be the cause. This observation demonstrates the need to investigate H_2S temporal and spatial distribution (horizontal and vertical) within swine housing during manure slurry agitation and removal events.

Muhlbauer et al (2008) collected high frequency (less than 1 minute sampling interval) H_2S concentration data at two points within the same confinement simultaneously and concluded considerable spatial variation in H_2S concentration can exist in a swine confinement during slurry agitation. More sampling points are necessary to characterize the distribution of H_2S within a swine confinement. Greater spatial resolution would provide an enhanced representation of the environment. An assessment of the conditions within the swine confinement will have greater value with an enhanced representation.

The burst characteristic of H_2S gas releases make it dangerous. Studies have shown that H_2S levels can change rapidly reaching lethal concentrations during agitation of manure in sub-floor pits (Ni et al, 2000; Muhlbauer et al 2008; Patni and Clarke 2003). Although a mobile lab containing gas analysis equipment is highly accurate (Hoff et al 2006; Ni et al, 2000; Ni et al, 2002), it has several limitations including: installation time, low mobility of sampling locations, and asynchronous sampling. Short duration bursts could be concealed due to the time interval and stabilization period associated with asynchronous sampling of multiple locations utilizing a mobile lab (Ni et al 2000). Due to the dynamics of the environment multiple locations need to be sampled at high frequency simultaneously to capture the distribution of H_2S bursts. This can be accomplished through the use of an array of electrochemical sensors which have demonstrated the ability to perform similarly to a pulsed fluorescence analyzer during swine slurry agitation (Muhlbauer et al, 2008). Electrochemical sensors interfaced with a wireless data network allow high frequency transmission of concentration data from multiple sample locations. This paper discusses the development of a wireless H_2S sensor network to quantify H_2S concentration data within deep-pit swine housing.

Safety Emphasis

The wireless H₂S sensor network will be used to collect concentration data in deep-pit swine buildings before, during, and after manure slurry agitation and removal events. Entry into a swine facility during slurry agitation and removal is never recommended. The H₂S data collected using this wireless sensor network will be compared to current suggested worker exposure levels to assess the risk associated with entry before, during, and after manure slurry agitation and removal events. H₂S distribution maps will be developed to suggest management practices to better safeguard animals during these events.

Materials and Methods

The wireless H₂S sensor network was designed to measure H₂S concentrations in multiple locations within a swine facility and transmit the data to an outside location where an operator can monitor the conditions real-time. Multiple H₂S gas sensors measure gas concentrations within the swine production facility, and a wireless data communications network transmits gas sensor data to a central location for remote monitoring, analysis, and storage. The network will be installed in a swine facility and collect data before, during, and after a slurry agitation and removal event. After data collection the network will be removed, disinfected, and reinstalled at another swine facility.

Hydrogen Sulfide Gas Measurement

Previously, Muhlbauer et al (2008) tested multiple commercially available H₂S sensors for response time, accuracy, and repeatability in a controlled laboratory environment. A H₂S sensor (PT-295 HEC H₂S, Pem-Tech Inc) performed very well in comparison to a lab grade H₂S analyzer (Model 45C, Thermo Environment Instruments) in both controlled lab and sub-floor slurry storage swine house environments. The sensor has demonstrated excellent durability in the detection system during its use by multiple slurry applicators since October 2007. The electrochemical sensor has a 0 to 500 ppm range to capture potential high concentration bursts during slurry agitation and removal events from sub-floor swine slurry storages. The project team selected the Pem-Tech PT-295 HEC H₂S sensor for use in this project because of its familiarity, performance, and durability.

To determine if continuous exposure to H₂S would degrade the sensor reading, the sensor was exposed to H₂S for an extended period. Gradual signal degradation leading to unrepresentative sensor readings is called sensor drift. The sensor was tested for drift in a controlled environment within a fume hood at the Iowa State University Agricultural and Biosystems Engineering Department Agricultural Waste Management Laboratory.

To evaluate sensor performance 97 ppm (certified +/- 2%) (Matheson Tri-Gas, Joliet, IL) H₂S gas was used for drift testing. The test circuit used by Muhlbauer et al (2008) was employed to further evaluate the Pem-Tech PT-295 HEC. Figure 1 is a schematic of the test circuit. A digital dilutor controlling a zero air generator (produces clean, dry air free of SO₂, NO, NO₂, O₃, H₂S) was used to expose the sensor to a continuous airstream of 0 ppm (herein referred to as zero air). The test circuit consisted of Teflon® tubing and Teflon® coated electric solenoids. A switch controlled the solenoids to switch between zero air and 97 ppm H₂S. An in-line humidifier was installed to maintain procedure continuity. The sensor output was recorded using a Campbell Scientific CR10X data logger (Campbell Scientific Inc., Logan, UT).

During testing the sensor was initially calibrated to measure 97 ppm H₂S cylinder gas as 100 ppm H₂S. The sensor was allowed to warm up for over two hours before testing commenced. Initially the sensor was exposed to zero air to track the baseline output. The sensor was then

introduced to continuous H₂S cylinder gas for 10 hours. After 10 hours the sensor was exposed to zero air for a period of hours (overnight) to allow the sensor to stabilize. After stabilization the sensor was challenged to a 5 minute burst of H₂S, this challenge was repeated in triplicate. The H₂S sensor was then recalibrated and again triplicate challenged to 5 minute bursts of H₂S.




Figure 1. Lab test circuit for H₂S drift test.

Wireless Data Transmission Network

In the interest of mobilizing data collection quickly, the project team selected to purchase an out-of-the-box ready wireless network system. A SensiNet Wireless Networking System (SensiCast Systems, Needham, MA) was purchased to interface with the H₂S sensors. The SensiNet system is a turnkey wireless network system ready for installation out-of-the-box. The SensiNet wireless network system follows a star or multipoint to point network topology, shown in Figure 2 where wireless sensor nodes communicate directly with the gateway or network coordinator. While the range of this network is limited by the distance to the most distant node, the range can be extended with a SensiNet mesh router. The router acts as a hopping device where data to and from the nodes can pass through the router.




Figure 2. A schematic of multipoint to point (star) network topology.

To connect the H₂S sensor to the wireless node, the analog output of the H₂S sensor is tied to one of the two input ports of a current sensor node (CURR-1022, SensiCast Systems). Upon power-up the sensor self identifies into the network and transmits data to the central gateway. The SensiNet gateway (GWAY-1020, SensiCast Systems) is the hardware device that nodes report to and users can configure and manage the network through this gateway. The gateway has internal storage which can be configured to automatically upload to a computer via file transfer protocol (FTP), hypertext terminal protocol (HTTP), Modbus, and Open Database

Connectivity (ODBC). The system also boasts a host of connectivity options to automation software applications such as *LabView*, *Microsoft Excel*, among others. To access the network management options and view a graph of recent data using the built-in graphic user interface (GUI), a local area network (LAN) is established connecting the gateway and a computer using an Ethernet router. Figure 3 shows the components of the planned wireless sensor network.




Figure 3. The SensiNet wireless network was intended to transmit the H₂S sensor output through the gateway to the computer. The red dashed arrow indicates the SensiNet gateway would not transmit data to the LAN thus proving to be an inoperable system.

A range test was performed on the SensiNet wireless network to determine the maximum transmission distance. Initially, multiple wireless nodes were powered and placed near the gateway (less than 3 m separation distance) with a clear line of sight between the gateway and nodes to achieve maximum potential connectivity. To test the range of the wireless network, the gateway GUI was monitored while the wireless node was carried a distance until the node lost connection with the gateway. The test was performed multiple times with different nodes. A mesh router was not utilized to extend the range of the nodes.

The inoperability of the SensiNet wireless network caused the team to search for other wireless network technology to implement in this research. Recent advances in mesh networking technology have led to their implementation in agricultural environments (Darr and Zhao, 2008; Coates and Delwiche, 2008). In a mesh network topology, nodes can act as routing hops to transmit data from other nodes to the data sink as shown in Figure 4. The data sink node is the final destination for the data where the nodes can be monitored via connection to a computer.

The sink functions similarly to the previously described central gateway of the SensiNet wireless system, acting as the coordinator for the personal area network (PAN).




Figure 4. Zigbee nodes operate as a mesh (peer-to-peer) network to transmit data to the sink. The nodes can be monitored using a decoder and a RS232 connection to a computer.

Previous researchers (Hebel, 2006; Hebel et al, 2007; Darr and Zhao, 2008) utilized wireless network systems employing the Zigbee standard. Zigbee was developed under the IEEE 802.15.4 communication protocol (IEEE, 2003) and was designed for long battery life, low data rate, and low cost applications. Two network topologies can be defined for wireless modules utilizing the Zigbee protocol (multipoint to point or mesh). The advantage of a mesh network is range and reliability can be increased with the addition of nodes within range of one another to route data to the sink.

Results

Hydrogen Sulfide Sensor Drift Test

The H₂S sensor performed well during drift testing. During continuous long duration exposure the maximum error experienced was 6%. Minimal signal degradation occurred due to continuous exposure to H₂S. The results shown below illustrate sensor performance.

Figure 5 shows the performance of the H₂S sensor during continuous exposure to H₂S for 10 hours. The sensor was calibrated to measure 97 ppm H₂S as 100 ppm prior to test start up. The maximum error during this test was 6%, experienced during the first 10 minutes of the test. For the majority of the test the sensor output was 99 ppm, a 1% error from the sensor's calibrated value. Interestingly, the sensor registered 1 ppm within 1 minute of applying zero air, but returned to 15 ppm; gradually decreasing to zero output after 1.25 hours. H₂S flow was

interrupted for approximately 1.5 minutes near the 5.5 hour mark to refill the in-line humidifier. Once flow was restored the sensor returned to 99 ppm.




Figure 5. Graph of continuous long duration exposure to 100 ppm H₂S. H₂S gas applied at t = 0 and zero air at t = 10 hr. Measurements were taken in 10 second intervals.

After the sensor was drift tested its output during burst challenges was compared to burst challenges after recalibration. Figure 6 shows the average of each triplicate burst challenge before and after recalibration. The sensor demonstrates similar performance before and after recalibration. The sensor reached 90% of the applied concentration (T_{90}), at approximately 1 minute for both scenarios and returned to zero with minimal hysteresis.




Figure 6. Comparison of H₂S sensor reading to 100 ppm burst after drift test and after recalibration. H₂S burst initiated at t = 0 and zero air at t = 5 min. Measurements were taken in 10 second intervals.

Upon completion of the drift test the sensor had been exposed to 970 ppm-hours of operation without recalibration. During subsequent burst challenges the sensor reached over 1100 ppm-hours of operation until a recalibration was performed. The sensor outputs during the 100 ppm burst challenges before and after recalibration were very similar.

SensiNet Wireless Network Performance

A LAN was established connecting the gateway and two computers using an Ethernet router. When configuring the gateway to upload to the connected computer via FTP or HTTP, issues arose with no data transferred to the computer. The LAN was monitored using a network protocol analyzer (Wireshark, Wireshark Foundation) for data packet transmission between devices within the LAN. Data packet transmission was verified between two computers within the LAN; this verified the address of the server computer was correct. When the SensiNet gateway was configured to upload to the server on the computer, no data packets were transmitted by the gateway. The gateway should send a data packet requesting access to the specified server address even if the server address is incorrect. Thus the gateway was incapable of automatic transmission to a host computer using the manufacturer network management options. This led the team to diagnose the automatic data transmission function of the gateway to be defective.

A range test of the wireless nodes was attempted, but reliability issues led to inconclusive results. Ten sensor nodes were powered up and placed within 3 m of the gateway. When near the gateway the wireless nodes would unexpectedly drop from the network and report no

network available. After a period of time some nodes would rejoin while others would not. This would repeat unexpectedly and without reason. Of those nodes connected to the gateway, data could at times be displayed graphically using the provided software interface. When this data was manually exported from internal storage to the connected computer, the file would display no data.

SensiCast Systems provided no customer support and remained unreachable for a warranty claim. The proprietary architecture of the network along with inoperable equipment required complete replacement of the system.

Zigbee Wireless Network Implementation

Through collaboration with Dr. Matthew Darr¹ and Dr. Lingying Zhao² (¹Iowa State University, ²The Ohio State University), the team was able to utilize a wireless data acquisition system developed by Darr and Zhao, described in Darr and Zhao, 2008. The system required configuration for utilization in this project. First, the current output of the H₂S sensor required conversion to a voltage signal (Figure 7) to utilize an available analog-to-digital (A/D) channel on the wireless sensor node. The A/D channel is a maximum 1.2 VDC and has a programmable 5 to 12 bit resolution.




Figure 7. Circuit to convert 4-20mA H₂S sensor output to max 1.2V signal for A/D channel on wireless sensor nodes.


Using the manufacturer supplied software and the Ohio State University supplied configuration files, the wireless nodes and sink were configured to identify into the same channel on the same PAN allowing communication to begin upon startup. The Zigbee protocol automatically finds the route nodes utilized to transmit data to the sink, routing messages through another node if the sink is out of range. The data transmission interval is user-programmable and is currently set to 1 minute. The transmission interval can be decreased in the event finer temporal resolution is desired. Battery life is not expected to be an issue as monitoring events are expected to be 72 hours or less and power is supplied by a DC/DC (12 to 3) voltage converter connected to a 9Ah 12VDC sealed lead acid battery. This battery also provides power to the H₂S sensor via an additional DC/DC (12 to 24) voltage converter.

Conclusion

The H₂S sensor demonstrated excellent performance during drift testing and burst challenges. Although the maximum sensor error during drift testing was 6%, the signal degradation due to continuous exposure was minimal. A wireless H₂S sensor network utilizing this sensor as the gas measurement interface will suitably characterize high concentration H₂S in swine housing before, during, and after slurry agitation and removal events.


Due to the combination of defective equipment and poor customer service with the SensiNet wireless network from SensiCast Systems, the project team has collaborated with Darr and Zhao to utilize a wireless data acquisition system which has demonstrated success in a swine finisher where temperatures have been monitored for over 2 years. The system is configured to identify into the same channel on the same PAN upon startup and transmit data from sensor nodes to the data sink every 60 seconds. At the time of paper submission, the system is undergoing testing to confirm reliability and transmission capabilities and interfacing with the H₂S sensors.

The wireless H₂S sensor network will be deployed in a two-level matrix style grid within the AOZ of a deep-pit swine house prior to slurry agitation as shown in Figures 8a and b. Multiple locations will capture H₂S concentration data from sensors located at slat level and approximately 1.5 m above the slats. The data will then be used to characterize the spatial (horizontal and vertical) and temporal distribution of H₂S before, during, and after manure slurry agitation.



X Mobile Lab Sample Port
● Wireless H₂S Sensor Node

Figure 8a. Conceptual horizontal layout of wireless H₂S sensor nodes and fluorescence sample ports.



X Mobile Lab Sample Port
● Wireless H₂S Sensor Node

Figure 8b. Conceptual vertical layout of wireless H₂S sensor nodes and fluorescence sample ports.

H₂S concentrations are anticipated to be low (<10 ppm) during normal operational periods. A mobile lab with a fluorescence H₂S analyzer (Advanced Pollution Instrumentation Model 101E) with four sample locations (Figures 8a and b) within the animal area of the deep-pit swine house will also be installed to characterize low concentrations (<10 ppm).

Acknowledgements

This project is funded by the National Pork Board and the Iowa Pork Producers Association. Wireless network collaboration and assistance was provided by Dr. Matthew Darr¹ and Dr. Lingying Zhao². ¹ Iowa State University, ² The Ohio State University

References

- Coates, R. W., and M. J. Delwiche. 2008. Site-specific water and chemical application by wireless valve controller network. *In Proc. 2008 ASABE International Meeting*. ASABE Paper No. 084483
- Darr, M. J., L. Zhao. 2008. A wireless data acquisition system for monitoring temperature variations in swine barns. *In Proc. 8th International Livestock Environment Symposium*, 987-994. ASABE Publication No. 701P04808
- Donham, K. J. 1990. Health effects from work in swine confinement buildings. *American Journal of Industrial Medicine* 17:17-25.
- Donham, K. J., and K. E. Gustafson. 1982. Human occupational hazards from swine confinement. *Annals of the American Conference of Governmental Industrial Hygienists* 2:137-142
- Hebel, M. A. 2006. Meeting wide-area agricultural data acquisition and control challenges through Zigbee wireless network technology. *In Proc. 4th World Congress on Computers in Agriculture*, 234-239. ASABE Publication No. 701P0606
- Hebel, M. A., R. Tate, and D. Watson. 2007. Results of wireless sensor network transceiver testing for agricultural applications. *In Proc. 2007 ASABE International Meeting*. ASABE Paper No. 073077.
- Hoff, S. J., D. S. Bundy, M. A. Nelson, B. C. Zelle, L. D. Jacobsen, A. J. Heber, J.-Q. Ni, Y. Zhang, J. A. Koziel, and D. B. Beasley. 2006. Emissions of ammonia, hydrogen sulfide, and odor before, during, and after slurry removal from a deep-pit swine finisher. *Journal of the Air and Waste Management Association* 56:581-590.
- IEEE, 2003. Wireless medium access control (MAC) and physical layer (PHY) specifications for low-rate wireless personal area networks (LR-WPANs). IEEE Standard 802.15.4. The Institute of Electrical and Electronics Engineers.
- Muhlbauer, R. V., R. J. Swestka, R. T. Burns, H. Xin, S. Hoff, and H. Li. 2008. Development and testing of a hydrogen sulfide detection system for use in swine housing. *In Proc. 2008 ASABE International Meeting*. ASABE Paper No. 084203
- Ni, J.-Q., A. J. Heber, C. A. Diehl, R. K. Duggirala, and B. L. Haymore. 2002. Hydrogen sulphide emission from two large pig-finishing buildings with long-term high frequency measurements. *Journal of Agricultural Science* 138:227-236.
- Ni, J.-Q., A. J. Heber, C. A. Diehl, T. T. Lim, R. K. Duggirala, and B. L. Haymore. 2000. Burst releases of hydrogen sulfide in mechanically ventilated swine buildings. *In Proc. Odors and VOC Emissions 2000*. Alexandria, VA: Water Environment Federation.
- Patni, N. K., and S. P. Clarke. 2003. Gaseous emissions in swine barns and during slurry mixing in sub-floor pits. *In Proc. 2003 ASAE International Meeting*. ASAE Paper No. 034081
- Puck, J. 2008. *Personal communications*. October 30, 2008. Puck Custom Enterprises, a custom manure slurry removal and application business handling over 100 million gallons of manure slurry annually.